

AN ACT

ENTITLED, An Act to revise certain provisions regarding corrosion protection for tank piping systems and aboveground tanks containing flammable or combustible liquids and used in retail motor fuel dispensing operations.

BE IT ENACTED BY THE LEGISLATURE OF THE STATE OF SOUTH DAKOTA:

Section 1. That § 34-38-33 be amended to read as follows:

34-38-33. Any portion of a tank piping system that is in contact with the soil shall be protected from corrosion in accordance with chapter 34 of the International Fire Code, 2003 edition.

Section 2. That § 34-38-39 be amended to read as follows:

34-38-39. Tanks may not exceed an individual capacity of twelve thousand gallons and may not exceed an aggregate capacity of forty-eight thousand gallons. Any variance in excess of these amounts can only be granted by the division pursuant to chapter 1-26.

An Act to revise certain provisions regarding corrosion protection for tank piping systems and aboveground tanks containing flammable or combustible liquids and used in retail motor fuel dispensing operations.

I certify that the attached Act
originated in the

SENATE as Bill No. 11

Secretary of the Senate

President of the Senate

Attest:

Secretary of the Senate

Speaker of the House

Attest:

Chief Clerk

Senate Bill No. 11
File No. _____
Chapter No. _____

Received at this Executive Office
this _____ day of _____ ,

20____ at _____ M.

By _____
for the Governor

The attached Act is hereby
approved this _____ day of
_____, A.D., 20____

Governor

STATE OF SOUTH DAKOTA,
ss.
Office of the Secretary of State

Filed _____, 20____
at _____ o'clock __ M.

Secretary of State

By _____
Asst. Secretary of State